

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221121  
Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Friday, July 08, 2022

Corrective Action Required:

1	Misc	-Protect TJI joists per code -Ceiling grid support wires too loose. Twist 3 times -NM cables not allowed to be exposed. Cover NM cables with material with 20-minutes fire protection -Complete ducting to ceiling air supply registers -Complete bathroom exhaust to outside -Complete return air per plan
---	------	--

**Comments:**