

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213817
Address: 3746 SW MARYVILLE PL, LEES SUMMIT, MO 64082
Inspected On: Thursday, July 14, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 8/13/2022 9:47:42 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Thursday, July 14, 2022

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks -gutters and downspouts -maintain erosion control until sod is placed - seal firewall penetration SE cable basement, this requires UL approved fire rated intumescent caulk
---	------	---

UNIT 3746:

- final grade and sod
- splash blocks
- gutters and downspouts
- maintain erosion control until sod is placed

TCO EXPIRATION 8/13/22