

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220125

Address: 1231 NW MAIN ST, LEES SUMMIT, MO 640861220 NW MAIN ST, LEES SUMMIT, MO 640861220 NW
MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection	John Jackson	Partial	Thursday, July 14, 2022

Informational:

1 Misc

07/06/22 Wednesday (Central Plumbing)

Contractor installed approximately 80' of 36" RCP from storm box B-3 to B-4.

Informational:

2 Misc

7-14-22 RH. 36" Storm B-9 to G-1 approximately 55' was ran and filled over.

Comments: