

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20220125

Address: 1231 NW MAIN ST, LEES SUMMIT, MO 640861120 NW MAIN ST, LEES SUMMIT, MO 640861220 NW  
MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	John Jackson	Partial	Thursday, July 14, 2022

Informational:

1 Misc 03/23/22 Wed (Kadean Construction)  
Erosion control measure and devices were established at the start of the project and the appear to be functioning correctly.

Corrective Action Required:

2 Misc 05/05/2022 Thursday (HB Const./ KADEAN)  
Matt Glikbarg with Lee's summit Public Works called to inform me that silt fencing was compromised near the train tracks. I talked with Paul Bersbach of KADEAN about the silt fencing issue and the fencing contractor is going to be on site to correct all issues. I toured the site and note several area effected by the inclement weather conditions.

Informational:

3 Misc 5-12-22 AN the silt fence that i did see looked in good working order

Informational:

4 Misc 7-14-22 RH. Erosion control and silt fence in place and in working order.

**Comments:**