

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213190
Address: 1924 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Failed	Thursday, July 14, 2022

Corrective Action Required:

1	Misc	-Ground service to copper water line per code
---	------	---

Corrective Action Required:

2	Misc	inspection denied due to erosion control still not in compliance.
---	------	---

Comments: