

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213190  
Address: 1924 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Mitchell Schwarz	Failed	Thursday, July 14, 2022

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	9-8-21 EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -Restore silt fence at perimeter of lot
---	---	--

Corrective Action Required:

2	Misc	erosion control still not in compliance silt fence maintain vegetation
---	------	--

**Comments:**