

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210734  
Address: 1514 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - R</b>	Robb Popp	Passed	Thursday, July 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	It appears that the MH (4511) in the back of the lot has been hit, there is also debris in the line. Contractor needs to make corrections to the MH.
---	-----------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**