CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Robb Popp Partial Thursday, July 14, 2022

Commercial

Corrective Action Required:

1 FIRST FLOOR AREA A:

Nail structural straps and fire caulk alarm lines throughout

133-incomplete

135-OK

136-vertical fireblocking 10' oc at party wall,

138-OK

140- support se cable, 142-fire caulk dwy in bath

137 OK 102-107 ok

Corrective Action Required:

2 SECOND FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS

Corrective Action Required:

3 THIRD FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B" UNITS AND CORRIDORS

Corrective Action Required:

4 STAIR TOWER 1 STAIR TOWER "A"

-3RD FLOOR OK

Corrective Action Required:

STAIR TOWER 2 STAIR TOWER "B"

-3RD FLOOR OK

Corrective Action Required:

6 STAIR TOWER 3 STAIR TOWER "C"

-3RD FLOOR OK

Comments: