

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20216366  
Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Adam Nacke	Passed	Thursday, July 14, 2022

Informational:

1 Misc 6-15-22 AN type 5 base is down and they are ready for proof roll

Corrective Action Required:

2 Miscellaneous Correction 6-16-22 AN we did a proof roll with a 20 ton load and it failed . There was 3 bad spots and they will dig up and replace

Informational:

3 Misc 6-17-22 AN crew is digging out the problem area and fixing them. We still need to do a proof roll on one of the side street.

6-20-22 AN crew did proof roll on the side street and it failed . ( problem areas were fixed and are good now ) pics attached

7-5-22 AN concrete crew is doing the first pour of the road and we did not need a proof roll because the curb proof roll was good and it has not rain since

**Comments:**