

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213997
Address: 605 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081605 NW REDBUD DR, Unit:A, LEES
SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Shawn Hoffman	Failed	Thursday, July 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	Derate feeder cables in attic for ambient temperatures (2017 NEC 310.15) OK TO RELEASE METERS UNITS A & B UNIT A NEEDS DERATED UNIT B IS COMPLETE
---	-----------------------------	--

Comments: