

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213997
Address: 605 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081605 NW REDBUD DR, Unit:A, LEES
SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, July 14, 2022

Corrective Action Required:

1	Misc	605 nw redbud unit A -Electrical service inspection failed and needs re inspection -Splash blocks Provide sod Unit B -Sod and splash blocks
---	------	---

Corrective Action Required:

2	Misc	inspection denied untill the rough-in and electrical have been addressed. The note to Mike Weisenborn , Mike is a project manger and is not a building inspector or the manager of building inspections. . contact Mark harding at 969-1216 Note" We are trying to resolve the derating issue but apparently there are no smaller 150amp breakers period. This is the first time we have ever had to do this. We have a call in to Mike Wisenborn and are waiting on how he recommends us resolving this issue."
---	------	--

MARK HARDING 07/08/2022 7:38 AM

Comments: