

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221052
Address: 3206 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|--------------|----------|-----------------------|
| Erosion Control | Mark Harding | Failed | Friday, July 15, 2022 |

| | |
|---|--|
| Corrective Action Required: | |
| 1 DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. |

Comments: