

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212467
Address: 4821 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, July 15, 2022

Corrective Action Required:

1	Misc	-maintain erosion control on lot until sod is placed and remove mud from sidewalks -no pier inspection performed covered patio -submit as graded plot plan -final grade and sod -splash blocks -install sliding glass door hardware, secondary toe lock required -jacuzzi tub motor access required -install basement egress window -mark dedicated receptacle in basement as not GFCI protected
---	------	--

Comments: