

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216073
Address: 520 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Not Ready	Friday, July 15, 2022

Corrective Action Required:

1	Misc	provide minimum 10psi at gas pressure gauge for inspection.
---	------	---

0 psi a pressure gauge
Mitchell Schwarz 07/15/2022 8:14 AM

Comments: