

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Friday, July 15, 2022

Corrective Action Required:

1 FIRST FLOOR

AREA A:

133-incomplete
135-OK
136-vertical fireblocking 10' oc at party wall- SEAL PENETRATIONS
138-OK
140- support se cable,
142-OK
137 OK
102-107 ok

Corrective Action Required:

2 SECOND FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS

Corrective Action Required:

3 THIRD FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS

Corrective Action Required:

4	STAIR TOWER 1	STAIR TOWER "A" -3RD FLOOR OK
---	---------------	----------------------------------

Corrective Action Required:

5	STAIR TOWER 2	STAIR TOWER "B" -3RD FLOOR OK
---	---------------	----------------------------------

Corrective Action Required:

6	STAIR TOWER 3	STAIR TOWER "C" -3RD FLOOR OK
---	---------------	----------------------------------

Comments: