

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20215334  
Address: 2043 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, July 15, 2022

Corrective Action Required:

1	Misc	-support hips garage-NOT DONE -address all ceiling joists taper cut more than 25%-NOT ADDRESSED -uncover covered patio or proved way to view-PROVIDE COLLAR TIES 4' OC, -fireblock top of furr out wall in laundry -USE APPROVED MATERIALS AND METHODS -fire block furr out wall at basement stairwell landing-SEE UPPER LANDING -anchor steel column in basement-NOT DONE -bond gas line-IDENTIFY CONDUCTOR AT BOTH ENDS
---	------	---

Corrective Action Required:

2	Misc	INSPECTION DENIED EROSION CONTROL NOT IN COMPLIANCE. Mitchell Schwarz 07/13/2022 10:48 AM
---	------	--

Still not in compliance  
7/15/22 11:10AM

**Comments:**