

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Passed	Friday, July 15, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	-FOOTINGS FOR (2) TRASH ENCLOSURES MAIN BUILDING- UFER LOCATED 7' WEST OF NE CORNER
---	----------------------------------	--

Comments: