

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204944
Address: 214 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, July 18, 2022

Corrective Action Required:

1	Misc	Obtain Lawn irrigation permit & submit back-flow Certification
		Provide Splash blocks
		Seal top of exterior light fixtures
		Provide secondary lock SGD
		Provide (2) 1/2 through bolts deck beam to post connection (2018 IRC Figure R507.5.1 (1))
		Provide 6" clearance wood siding to grade (2018 IRC R317.1 (5))
		Provide flashing above exterior horizontal trim master bedroom windows

Comments: