

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220013
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Patrick Schonfeldt	Partial	Monday, July 18, 2022

Corrective Action Required:

1	Misc	PARTIAL PIERS, (1) 24" X 36" FOR NW CORNER ROOF SUPPORT INSPECTED, (3) ADDITIONAL PIERS REQUIRED PER PLANS
---	------	--

7/18/22 (3) additional piers inspected, ok to pour, the (2) pier at front west side of deck need to be 36" below grade for frost depth

Comments: