

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220082  
Address: 3205 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, July 18, 2022

Corrective Action Required:

1	Misc	-seal top plate penetrations in garage N wall -fire block hvac chase to ceiling space(seal penetrations) -fire block garage E wall into furr down(see furr out wall right of fridge -address holes less than 2" from each other in floor joist above kitchen/great room(no letter for fix -fireblock left and right of great room windows into furr down(seal gaps) -seal top plate penetration at hvac -missing truss hangers onA14 -connect ufer ground to middle grounded bus bar
---	------	---

Comments: