

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214416
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, July 18, 2022

Corrective Action Required:

1	Misc	**APPROVED FOR EMPLOYEES TO STOCK AND TRAIN ONLY -Cut main Main bar floor drains to 1" above drain -Gfci at main bar service -Gfcis at expo -Backflow devices at all hard piped equipment -Label panels -Provide Panel schedules -Label exterior disconnects -Complete canopy and trash compactors -Escutcheon at riser room,kitchen, corridor, outside of bath -Complete exterior lighting west side -Provide Handrails at exterior steps -Complete parking lights south -Provide Permanent address -Obtain Health department final approval -Complete Trash enclosure gates -Complete all items from all other departments
---	------	---

Comments:

