

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215409
Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Monday, July 18, 2022

Corrective Action Required:

1	Miscellaneous Correction	ok to install ceiling tiles. below can be chaed at final. -Provide certification that fireproofing is installed to proper thickness , pending letter . -Provide Identification (stencil) at fire walls per code -Provide screening at CO2 tank at exterior
---	-----------------------------	---

Comments: