

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216532
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1	Misc	-Complete plumbing garage at master bathroom, stub trap through floor, fireblock tub trap NOT DONE
---	------	---

****OK TO INSULATE, REMOVE INSULATION FROM INSPECTION ITEMS**

Comments: