

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211894
Address: 2111 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1 Misc

- erosion control to remain in compliance until sod is in place
- sod
- gutt
- check water meter at time of sod
- spark rings at kitchen outlets as will be required
- security screws at basement door
- address siding from concrete patio and side wall at back of lot
- label all non GFCI outlets in unfinished spaces
- complete stairs in garage
- provide ladder at egress window well to code

Comments: