

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211947
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -final driveway inspection required, contact development services to schedule -final grade and sod -splash blocks -provide gravel base water meter pit -provide joist hanger at joist to beam connection deck -(2) 1/2" through bolts each post/beam connection deck -GFCI front porch test hot/neut reverse -cover plate fridge outlet, basement outlets -secure main water line to foundation wall
---	------	--

Comments: