

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213077
Address: 4420 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1	Misc	-final driveway inspection required contact development services to schedule -submit as graded plot plan for review and approval -final grade and sod -water meter to grade, maintain 14"-18" from meter to lid -gravel base at water meter pit -provide approved ledger lags at deck, truss structural screws not allowed -label all dedicated receptacles at garage and unfinished basement not GFCI protected -cover plates all outlets
---	------	---

Comments: