

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213383
Address: 3204 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Friday, July 08, 2022

Corrective Action Required:

1	Misc	-sod, erosion control, splashblocks, sump discharge. -driveway sidewalk approval. -uncover water meter. -locate sewer tracer wire. -attic acces cover in garage. -seal and rock bottom of boxouts in garage, seal sides of boxouts. -basment outlet at stair wall not gfci. -bottom step at bassement stairs over 7 3/4" , check all when corrected.
---	------	---

Comments: