

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213809
Address: 3829 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1	Misc	-address plumbing/electrical bores in floor joists kitchen less than 2" apart ...(REPAIR PEX BORES CLOSER THAN 2" AS WELL ABOVE KITCHEN PER ENGINEER LETTER)
---	------	---

Comments: