

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221783
Address: 1117 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Khanh Nguyen	Failed	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	-WATER SERVICE LINE MUST BE MIN 42" BELOW GRADE. CURRENTLY AT 27" FROM GRADE AT FOUNDATION WALL
---	------	---

Comments: