

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211947
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, July 20, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 8/20/2208 12:12:26 PM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	TCO until 8/20/22 -resolve outstanding inspection fees -final grade and sod -splash blocks -provide gravel base water meter pit -(2) 1/2" through bolts each post/beam connection deck -GFCI front porch test hot/neut reve
---	------	---