

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213077
Address: 4420 SW ALABASTER CIR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, July 20, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 8/20/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 8/20/22 -final grade and sod -water meter to grade, maintain 14"-18" from meter to lid -gravel base at water meter pit
---	------	---