

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212682
Address: 1841 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	-Obtain lawn irrigation system permit -raise water meter lid to grade, maintain 14"-18" clearance from top of meter to top of lid -Final driveway inspection required, contact development services to schedule -submit as graded plot plan for review and approval -gutters and downspouts -splash blocks -outlet covers, GFCI protection outlets at garage -provide security screws at back door -provide ladder at basement egress well
---	------	--

Comments: