

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214290
Address: 1399 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Wednesday, July 20, 2022

Corrective Action Required:

1 Misc

- COMPLETE ROCK ON UNFINISHED SIDE
- FIRE CAULK ALL THROUGH PENETRATIONS AND GAPS
- COMPLETE ASSEMBLY IN 105
- FIRE COLLARS AT DWV PENETRATION

****CORRECT THE ABOVE DEFICIENCIES; COMPLETE FIREWALL TO EXTERIOR WALLS; SCREW FIRE GB TO WALL PLATE; HAVE A CITY-APPROVED SET OF PLAN ON SITE**

Comments: