

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215297
Address: 1522 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	-fine grade and sod -provide as graded plot plan after sod -check water meter at time of final grade and sod -hardware at read slider -tamper resistant caps at A/c unit -check smokes and everything in basement when cleaning crew is not in home
---	------	--

Comments: