

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213052

Address: 3819 SW WALSH DR, LEES SUMMIT, MO 64082 3817 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, July 20, 2022

Corrective Action Required:

1 Miscellaneous
Correction

3817&3819

- obtain lawn irrigation system permit
- permanent addresses meter can and disconnects
- set sewer tracer box to grade

3817 and 3819 ok for TCO, TCO EXPIRES 7/29/22

3817

- Sump pump extension
- Handrail required at deck stairs
- Provide landing at deck stairs flight (13 1/4" drop to grade)

3819

- Sump pump extension

Comments:

