

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216155  
Address: 2958 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector: | Outcome: | Date:                    |
|----------------------------|------------|----------|--------------------------|
| <b>Sidewalk Inspection</b> | Eric Sharp | Partial  | Wednesday, July 20, 2022 |

Informational:

1 Misc

Sidewalk was framed up with aggregate in and compacted. 7/12/22 ES

Most parts of sidewalk meet LS and ADA spec; however, the southern portion of sidewalk is covered with dirt from grading. Will reinspect once sidewalk is all cleared. 7/20/22 ES

**Comments:**