

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213954

Address: 2015 SW OSAGE DR, LEES SUMMIT, MO 64082 2017 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Not Ready	Wednesday, July 20, 2022

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks all downspout and sump pump discharge locations, min 36" discharge from foundation -provide permanent address at electric meter cans and disconnects -provide gravel base at water meter pit
---	------	---

UNIT 2015 OK

7/20/22 - INSPECTION DENIED, UNIT 2017 NOT READY FOR INSPECTION

Comments: