

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, July 20, 2022

Corrective Action Required:
1 FIRST FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS EXCEPT AS NOTED:
133-incomplete

Corrective Action Required:
2 SECOND FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS

Corrective Action Required:
3 THIRD FLOOR THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS
AREA "B" UNITS AND CORRIDORS

AREA "C"
313 ok
355-fire block ceiling line at bed
357- fire block ceiling line at bed,
352-add stud in corridor wall-stud over bored
359-ok

354-ok
361-strap at dryer duct, fire caulk dead space, address broken truss at back
bed exterior wall, h2.5 at master closet
356-secure sec at panel
363- fireblocking at ceiling line bedroom, add stud st corridor wall
315-ok
358-ok
316-ok
365-fireblock ceiling line at bed
317-ok
318-ok
360-seal gaps at vertical fireblocking, fireblock at ceiling line, h2.5s at load
bearing wall
319-324-ok
367-strap at dryer vent,

Corrective Action Required:

4	STAIR TOWER 1	STAIR TOWER "A"
		-3RD FLOOR OK

Corrective Action Required:

5	STAIR TOWER 2	STAIR TOWER "B"
		-3RD FLOOR OK

Corrective Action Required:

6	STAIR TOWER 3	STAIR TOWER "C"
		-3RD FLOOR OK

Comments: