

ANALYTICAL REPORT

July 14, 2022

Work Order: 1FG1205

Page 1 of 3

Report To
Tom Taylor City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 07/13/2022 12:20PM Collector: Taylor, Tom Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Holthouse Construction

Project Number: Woodland Glenn

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FG1205-01 #1				Matrix:Drink Wtr		Collected: 07/13/22 09:40	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
1FG1205-02 #2				Matrix:Drink Wtr		Collected: 07/13/22 09:48	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
1FG1205-03 #3				Matrix:Drink Wtr		Collected: 07/13/22 09:55	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
1FG1205-04 #4				Matrix:Drink Wtr		Collected: 07/13/22 10:05	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0565	9223B-QT	CLJ	07/13/22 16:45	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

ANALYTICAL REPORT

July 15, 2022

Work Order: 1FG1446

Page 1 of 3

Report To
Tom Taylor City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 07/14/2022 11:08AM Collector: Taylor, Tom Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Holthouse Construction

Project Number: Woodland Glenn

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FG1446-01 #1				Matrix:Drink Wtr		Collected: 07/14/22 10:08	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
1FG1446-02 #2				Matrix:Drink Wtr		Collected: 07/14/22 10:18	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
1FG1446-03 #3				Matrix:Drink Wtr		Collected: 07/14/22 10:21	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
1FG1446-04 #4				Matrix:Drink Wtr		Collected: 07/14/22 10:28	
Total Coliforms	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	
E. Coli	<1.0 MPN/100ml	1.0	1FG0690	9223B-QT	CLJ	07/14/22 15:45	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.