

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222195
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Failed	Thursday, July 21, 2022

Corrective Action Required:

1	Misc	Verify that the pool shell bonding clamps are listed to be buried into concrete
**These clamps are verified to be connected to copper water tubing only. They are not designed for burial in concrete or connection to rebar		

Comments: