

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216307
Address: 3120 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, July 13, 2022

Corrective Action Required:	
1 Misc	Provide minimum 10psi at pressure gauge for gas line.
Corrective Action Required:	
2 Misc	inspection denied due to lack of erosion control. Mitchell Schwarz 07/13/2022 9:16 AM

Comments: