

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216307
Address: 3120 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, July 21, 2022

Corrective Action Required:

1 Misc

- nail top plate to header at pfh
- fire block furr down end in garage with dwv
- midway strap dwv 2" or less in stud bays
- fire block furr out wall for dwv into furr down in garage
- nail top plate to header at all cspf
- lib bracing bed 4 to plans
- solid blocking under kitchen island per plans

Comments: