

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216315
Address: 3216 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Steve Robbins	Partial	Thursday, July 07, 2022

Informational:
1 Misc Sidewalk has been formed, has 4" of rock and it has been compacted. Ready to pour. Steve Robbins 07/07/2022 4:09 PM

Comments: