

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220403
Address: 3213 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 19, 2022

Corrective Action Required:

1 Misc

- address holes in floor joist above garage near furr down for dwv drilled closer than 2" to edge
- address broken bath vent line above great room
- address over bored stud at fireplace
- address over bored stud above bed 5 closet for dwv
- hold downs for gt truss above bath 2 (install correctly)
- protect NM With in 6' of attic access 2nd floor
- missing hanger at N most front stoop truss(patio covered)
- missing truss hangers at back patio (covered)
- flood lamp at back of home

Comments: