

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215699
Address: 1917 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Diana Johnson	Passed	Tuesday, July 19, 2022

Informational:
1 Misc On 9.14.2022 I conducted a sidewalk inspection and pass the sub-grade to pour concrete

9.19.2022 sidewalk appears to be in compliance.

Comments: