

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220622  
Address: 2026 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, July 14, 2022

Corrective Action Required:

1	Misc	footing poured without inspection, provide third party inspection report.
---	------	---

Third party inspection does not meet the requirements of the city's third party footing inspection report.

**Comments:**