

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213399
Address: 2938 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, June 30, 2022

Corrective Action Required:

1	Misc	TCO until 7/8/22 -Address siding from ground at back of lot (less than 6") -lower water meter ring and lid to grade (maintain 14-18" from meter top to meter lid)
---	------	---

Comments: