

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215487  
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Diana Johnson	Passed	Thursday, July 14, 2022

Informational:  
1 Misc

On 7.11.2022 I conducted a sidewalk inspection of the subgrade for public sidewalk that was not in the ROW and passed it to pour concrete.

On 7.12.2022 I conducted a sidewalk inspection in the ROW and passed it to pour concrete.

The approximately 50 ft of sidewalk that extends to the P/L must be re-surveyed to improve drainage the existing area inlet.

7.14.2022 Sidewalk appears to be in compliance.

**Comments:**