

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20215487  
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Mitchell Schwarz	Partial	Wednesday, July 13, 2022

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	-2" conduit for communication lines from 26th st curb line to building
---	--	--

Corrective Action Required:

2	Misc	conduit for light pole bases to be trenced 18" deep, 24" deep if under parking lot.
---	------	---

Corrective Action Required:

3	Misc	Inspection under ground conduit for light poles nort and south side okay to cover. East side to be dug deeper
---	------	---

East side in compliance.  
Mitchell Schwarz 07/13/2022 9:33 AM

**Comments:**