

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214631
Address: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Diana Johnson	Passed	Monday, July 11, 2022

Informational:

1 Misc

On 3.16.2022 the following manholes passed the vacuum test:

MH 1-2

MH 1-3

The manholes labeled MH 1-4 and 2-1 failed the vacuum test

On 3.21.2022 Manholes 1-4 and 2-1 passed the vacuum test @ 10 lbs of pressure for 3 mins.

Comments: